

Basalt Fiber Geo-grid Certificate of Analysis

Q/J8.2.4-08-06

Delivery time: 2017-11-3

Specification:

Batch No. : 201706F19

Basalt Fiber Geo-grid 50*50-1m

Quantity: 400m²

Quality Standard: Q/GBF 031-2016

Inspection records

No.	Project		Standard Requirements	Test results	Results
1	weave	-	Geo-grid	Line	Qualified
2	Exterior	-	No dirty or oil spot, or defects which affect to use	Line	Qualified
3	width	cm	100±1	100.5	Qualified
4	Gram Weight	g/m ²	350±8%	353	Qualified
5	Oil Content (%)	%	≥8%	10.2	Qualified
6	Warp Break Strength	N/50mm	≥3000	4667	Qualified
7	Weft Break Strength	N/50mm	≥3000	4781	Qualified

Integrated to determine:

Upon examination of this batch of qualified products

Re-Checker: Jiajia-Lv

Checker: Qingling-Yang

Date: 2017-11-3